

MINEOLA WATER UTILITIES

MONTHLY ACTIVITY REPORT

MONTH OF: **December, 2018**

WATER:

Bacteriological Analysis.....	06
Pump Station Inspections.....	124 Hrs.
Customer Water Connections.....	43
Customer Water Disconnections.....	40
Turn water off for leak	18
Reread	03
Water Leaks Reported.....	10
Paid turn water back on	02
Locate Water Lines for Others.....	05
O & M Water Production & Distribution System (hours).....	372 hrs.
Miscellaneous	27
Pulled meter logs	06
Number of water Meters Read.....	2,701
Number of active accounts.....	2,424 29 city acct.
Disconnects for Non-Payment.....	00
Change meter register -----	0
Repairs complete turn water on-----	06
PRODUCTION & TREATMENT	
Water Produced in Million Gallons.....	13.515 M.G.
Average Usage per Day.....	.. 0.435 M.G
Highest Usage per Day.....	. 0.663 M.G.
Pounds of Disinfectant Used.....	445 lbs.
Average Pounds of Disinfectant Used per Day.....	14.3 lbs.
Pounds. Of Sequestering Agent Used.....	092 .00 lbs.
Average Pounds of Sequestering agent used per Day.....	3.0 lbs.
Pounds of Fluoride Used.....	126 lbs.
Average pounds of Fluoride Used	4.0 lbs.

MINEOLA WATER UTILITY MONTHLY ACTIVITY REPORT

WASTEWATER:

Sewer Stoppages Reported.....	19
Customer Stoppages.....	15
Lift Station Inspections Performed.....	124 hrs.
Sewer Taps Installed -----	0
O & M of Wastewater Collection System (hours).....	372 hrs.
Number of Feet of sewer Main cleared.....	600 ft.

UTILITY MAINTENANCE:

Vehicle Maintenance.....checked daily
Older trucks check for mechanical problems and returned to service.

Equipment Maintenance..... 093 hrs. EST.

Submitted by: Rolando Ortega

Water: Dept

Date: 01/03/2019