

Account Number	S T	Customer Name/Address Desc	Work Order Number	Work Order Description	Date/Time Issued	Date/Time Requested	Date/Time Completed	Units	Meter Reading	Read Date	Meter Number	Special Meter ID	Special Meter Id 2
001-0003100-000	A	MINEOLA COMMUNITY BANK 215 W. BROAD	11443	Sewer Back Up Instructions: Robin A. called and said they need sewers run in their area. ad like sewer Field Comment: no stoppage, line clear	05/02/19-08:07	05/02/19-08:07	05/02/19-10:08	1		05/02/19	9955386	10181996	
010-0000500-003	A	KINDNESS KOTTAGE 316 E. BROAD	11448	Sewer Back Up Instructions: Field Comment: ran and cleared sewer cleanout	05/02/19-11:28	05/02/19-11:28	05/03/19-10:09	1		05/03/19	9957383	10207478	
008-0013300-002	A	DAILEY CHAD 709 S. PACIFIC	11462	Sewer Back Up Instructions: Sewer backing up between building & highway Field Comment: Ran customer clean out to clear. RO	05/06/19-08:29	05/06/19-08:29	05/06/19-10:30	1		05/06/19	9955630	10210645	
002-0029000-000	A	V.F.W. POST 671 W. BROAD	11491	Sewer Back Up Instructions: Field Comment: checked sewer manholes and they weren't stopped up, they were running really slow due to rain water infiltration into the sewer system, talked to the vfw.	05/08/19-12:59	05/08/19-12:59	05/09/19-09:24	1		05/09/19	8537067	10278954	
004-0013100-000	A	DONOHUE G. M. 105 CIRCLE DR.	11492	Sewer Back Up Instructions: Sewer is backing up inside of house Field Comment: Ran customer clean out & cleared stoppage. FZ	05/08/19-13:16	05/08/19-13:16	05/08/19-14:52	1		05/08/19	7877162	10278521	
004-0025000-002	A	MINEOLA HEALTHCARE 716 MIMOSA BUILDING	11495	Sewer Back Up Instructions: Sewer backing up at roadway Field Comment: Everything is fine. Inflow is more than what the treatment plant can handle for now. JC	05/09/19-07:32	05/09/19-07:32	05/09/19-10:31	1		05/09/19	42526248	07408074	
005-0022100-003	A	PETTIJOHN DAVID & LAURIE 150 E. LOOP 564	11499	Sewer Back Up Instructions: sewer back up in both bathrooms. please run sewer Field Comment: cleared sewer main	05/09/19-12:17	05/09/19-12:17	05/10/19-09:26	1		05/10/19	10070650	10145915	
004-0027600-000	A	MCCREARY B. B. 1033 MIMOSA	11559	Sewer Back Up Instructions: Field Comment: ran main stoppage no one home	05/17/19-13:24	05/17/19-13:24	05/20/19-12:54	1		05/20/19	9956856	12097613	
008-0013300-002	A	DAILEY CHAD 709 S. PACIFIC	11586	Sewer Back Up Instructions: Sewer backing up in front of building Field Comment: No stoppage found. RO	05/22/19-09:26	05/22/19-09:26	05/22/19-11:09	1		05/22/19	9955630	10210645	
008-0013300-002	A	DAILEY CHAD 709 S. PACIFIC	11613	Sewer Back Up Instructions: Sewer back up again. Customer has video of problem. Wants someone there first thing today. Field Comment: installed cleanout and ran line with sewer machine	05/28/19-07:31	05/28/19-07:31	05/29/19-10:36	1		05/29/19	9955630	10210645	
001-0022300-003	A	ALLEN ZANA MARCI 414 GILES STREET	11615	Sewer Back Up Instructions: Field Comment:	05/28/19-09:25	05/28/19-09:25					8805944	10265380	

ubawotr
bjames

CITY OF MINEOLA
Work Order Tracking Report By Requested Date
Requested From: 05/01/2019 To: 05/31/2019

06/10/19
07:54

Page: 2

Account Number	S T	Customer Name/Address Desc	Work Order Number	Work Order Description	Date/Time Issued	Date/Time Requested	Date/Time Completed	Units	Meter Reading	Read Date	Meter Number	Special Meter ID	Special Meter Id 2
004-0027600-000	A	MCCREARY B. B. 1033 MIMOSA	11641	Sewer Back Up	05/30/19-14:42	05/30/19-14:42	05/31/19-10:47	1		05/31/19	9956856	12097613	
				Instructions:	PLEASE RUN SEWER AGAIN								
				Field Comment:	we never ran the sewer. Plumber ran one of the toilets, and told customer he will have to have a cle anout installed so we can run it. Only bathroom is backed up.								
004-0013100-000	A	DONOHUE G. M. 105 CIRCLE DR.	11643	Sewer Back Up	05/31/19-07:49	05/30/19-20:30	05/30/19-21:26	1		05/30/19	7877162	10278521	
				Instructions:	Sewer back up								
				Field Comment:	Ran sewer main & cleared. Called out by dispatch. FZ								
Number of work orders:		13	Units:	12	Completed:	12	Not Completed:	1					