

CITY OF MINEOLA
Work Order Tracking Report By Requested Date
Requested From: 06/01/2019 To: 06/30/2019

Account Number	S T	Customer Name/Address Desc	Work Order Number	Work Order Description	Date/Time Issued	Date/Time Requested	Date/Time Completed	Units	Meter Reading	Read Date	Meter Number	Special Meter ID	Special Meter Id 2
008-0006900-006	A	CHRIETZBERG JUDITH 507 LANDERS	11654	Sewer Back Up Instructions: Field Comment: cleanout is dry, customer will need to call a plumber. talked with customer	06/03/19-13:11	06/03/19-13:11	06/03/19-16:36	1		06/03/19	08719903	10319864	
004-0012900-002	A	ROMAN ANTHONY 145 CIRCLE DR.	11668	Sewer Back Up Instructions: toilet gurgling and cap blew off from clean out. please run our line Field Comment: ran cleanout and unstopped	06/05/19-08:02	06/05/19-08:02	06/06/19-09:55	1		06/06/19	7827172	12099569	
003-0006600-007	A	MINEOLA MEMORIAL LIBRARY 313 N. PACIFIC	11685	Sewer Back Up Instructions: HAS BEEN GOING ON FOR A FEW DAYS PER HUSBAND. PLEASE RUN FRI MORNING Field Comment: customer called back after 5 and talked to dispatch. they sent Justin to run thurs...cleared	06/06/19-17:02	06/06/19-17:02	06/07/19-10:21	1		06/07/19	9957202	12091960	
005-0006210-000	A	CRENSHAW HWY 80 CAR WASH 1217 N. PACIFIC	11700	Sewer Back Up Instructions: Sewer back up Field Comment: Ran sewer main & cleared. JC	06/10/19-15:39	06/10/19-14:00	06/10/19-14:45	1		06/10/19	52522167	07405882	
002-0028900-002	A	R C TIRE CENTER - MORALES 675 W. BROAD	11717	Sewer Back Up Instructions: Field Comment: ran cleanout not stoppage found customer will call plumber	06/12/19-11:18	06/12/19-11:18	06/12/19-14:49	1		06/12/19	10474109	10927526	
010-0009000-006	A	SWANNER TIMOTHY 218 HARRIS STREET	11739	Sewer Back Up Instructions: CUSTOMER CAME IN OFFICE AND SAID THE CITY CAME OUT AND DUG DITCH OUT AND HIT SEWER LINE. NOW, HE SA Y SEWER IS RUNNING OUT. PLEASE CK ASAP Field Comment: ran and cleared sewer stoppage at clean out. sewer line not broken	06/17/19-10:54	06/17/19-10:54	06/17/19-17:00	1		06/17/19	9955612	10147243	
004-0010500-010	A	THOMPSON MADELYN 411 E. MC DONALD	11745	Sewer Back Up Instructions: give work order back to me so I call call Reagan the owner. he thinks we replaced sewer line last y ear. Field Comment: Rolando said clean out that we put in is dry. problem will be from clean out up drive or under hous e. told Reagan this	06/18/19-08:38	06/18/19-08:38	06/18/19-10:56	1		06/18/19	9957242	12097984	
003-0001600-001	A	GODWIN ALLISON 512 N. JOHNSON	11746	Sewer Back Up Instructions: please run city line. 500 block toilets running slow Field Comment: rain main and washed it out. No stoppage found	06/18/19-08:42	06/18/19-08:42	06/18/19-14:52	1		06/18/19	8592173	10269582	
005-0003600-008	A	GREGORY BRITTANY LANE 1050 N. JOHNSON	11814	Sewer Back Up Instructions: Field Comment: no stoppage found customer will call a plumber	06/26/19-13:27	06/26/19-13:27	06/26/19-16:32	1		06/26/19	10070744	10274067	
008-0007600-004	A	BERRY LAGARIA 408 MC DANIEL STREET	11819	Sewer Back Up Instructions: Sewer back up Field Comment: Ran sewer clean out & cleared stoppage. RO	06/27/19-07:37	06/26/19-20:32	06/26/19-21:40	1		06/26/19	9955533	10208889	
010-0000500-003	A	KINDNESS KOTTAGE 316 E. BROAD	11826	Sewer Back Up Instructions: RUN SEWER....TOLIETS ARE BACKING UP Field Comment: ran cleanout and unstopped	06/28/19-12:27	06/28/19-12:27	07/01/19-10:24	1		07/01/19	9957383	10207478	

ubawotr
bjames

CITY OF MINEOLA
Work Order Tracking Report By Requested Date
Requested From: 06/01/2019 To: 06/30/2019

07/08/19
13:50

Page: 2

Account Number	S T	Customer Name/Address Desc	Work Order Number	Work Order Description	Date/Time Issued	Date/Time Requested	Date/Time Completed	Units	Meter Reading	Read Date	Meter Number	Special Meter ID	Special Meter Id 2
004-0013500-002	A	MC GEE COLTEN D 132 CIRCLE DR.	11828	Sewer Back Up	06/28/19-13:41	06/28/19-13:41	07/01/19-10:25	1		07/01/19	7877163	10318550	
				Instructions:									
				Field Comment:	ran cleanout and unstopped								
002-0023600-002	A	PRUITT HAYES GAY 1628 W. BROAD	11849	Sewer Back Up	07/02/19-14:52	06/28/19-14:52	07/02/19-14:54	1		07/02/19	10474118	10923221	
				Instructions:	Rolando and Frankie ran customers line and cleared it								
				Field Comment:	ran customers line and cleared								
Number of work orders:		13	Units:	13	Completed:	13	Not Completed:	0					