

# MINEOLA WATER UTILITIES

## MONTHLY ACTIVITY REPORT

MONTH OF: July, 2019

### WATER:

Bacteriological Analysis.....	06
Pump Station Inspections.....	124 Hrs.
Customer Water Connections.....	45
Customer Water Disconnections.....	35
Turn water off for leak .....	04
Reread .....	06
Water Leaks Reported.....	19
Paid turn water back on .....	22
Locate Water Lines for Others.....	02
O & M Water Production & Distribution System (hours).....	496 hrs.
Miscellaneous .....	30
Pulled meter logs .....	03
Number of water Meters Read.....	2,703
Number of active accounts.....	2,436 29 city acct.
Disconnects for Non-Payment.....	25
Change meter register .....	02
Set Meter .....	03
Repairs complete turn water on.....	02
<b>PRODUCTION &amp; TREATMENT</b>	
Water Produced in Million Gallons.....	17.562 M.G.
Average Usage per Day.....	0.566 M.G.
Highest Usage per Day.....	0.822 M.G.
Pounds of Disinfectant Used.....	555 lbs.
Average Pounds of Disinfectant Used per Day.....	17.9 lbs.
Pounds. Of Sequestering Agent Used.....	118 .00 lbs.
Average Pounds of Sequestering agent used per Day.....	3.8 lbs.
Pounds of Fluoride Used.....	144 lbs.
Average pounds of Fluoride Used .....	4.6 lbs.

# MINEOLA WATER UTILITY MONTHLY ACTIVITY REPORT

## WASTEWATER:

Sewer Stoppages Reported.....12  
Lift Station Inspections Performed..... 124 hrs.  
Sewer Taps Installed ----- 0  
O & M of Wastewater Collection System (hours)..... 496 hrs.  
Number of Feet of sewer Main cleared..... 1,650 ft.

## UTILITY MAINTENANCE:

Vehicle Maintenance.....checked daily  
Older trucks check for mechanical problems and returned to service.  
  
Equipment Maintenance..... 124 hrs. EST.

Submitted by: Rolando Ortega

Water: Dept

Date: 08/05/2019