

MINEOLA WATER UTILITIES

MONTHLY ACTIVITY REPORT

MONTH OF: **September, 2019**

WATER:

Bacteriological Analysis.....	06
Pump Station Inspections.....	120 Hrs.
Customer Water Connections.....	42
Customer Water Disconnections.....	41
Turn water off for leak	03
Reread	01
Water Leaks Reported.....	08
Paid turn water back on	21
Locate Water Lines for Others.....	04
O & M Water Production & Distribution System (hours).....	480 hrs.
Miscellaneous	20
Pulled meter logs	13
Number of water Meters Read.....	2,711
Number of active accounts.....	2,457 29 city acct.
Disconnects for Non-Payment.....	35
Change meter register	00
Set Meter	01
Repairs complete turn water on.....	01
Lock Meters.....	04
PRODUCTION & TREATMENT	
Water Produced in Million Gallons.....	18.037 M.G.
Average Usage per Day.....	0.601 M.G.
Highest Usage per Day.....	0.756 M.G.
Pounds of Disinfectant Used.....	600 lbs.
Average Pounds of Disinfectant Used per Day.....	20.0 lbs.
Pounds. Of Sequestering Agent Used.....	172 .28 lbs.
Average Pounds of Sequestering agent used per Day.....	5.7 lbs.
Pounds of Fluoride Used.....	205 lbs.
Average pounds of Fluoride Used	6.8 lbs.

MINEOLA WATER UTILITY MONTHLY ACTIVITY REPORT

WASTEWATER:

Sewer Stoppages Reported.....	15
Lift Station Inspections Performed.....	120 hrs.
Sewer Taps Installed -----	0
O & M of Wastewater Collection System (hours).....	480 hrs.
Number of Feet of sewer Main cleared.....	1,000 ft.

UTILITY MAINTENANCE:

Vehicle Maintenance.....checked daily
Older trucks check for mechanical problems and returned to service.

Equipment Maintenance..... 120 hrs. EST.

Submitted by: Rolando Ortega

Water: Dept

Date: 10/14/2019