

Account Number	S	Customer Name/Address Desc	Work Order Number	Work Order Description	Date/Time Issued	Date/Time Requested	Date/Time Completed	Units	Meter Reading	Read Date	Meter Number	Special Meter ID	Special Meter Id 2
002-0006500-006	F	MUNDT JANICE 317 BOWDOIN STREET	12356	Sewer Back Up	09/30/19-15:00	09/30/19-15:00	10/01/19-10:08	1		10/01/19	10474194	12095889	
Instructions: PLEASE RUN SEWER LINE,,,,,,,,,903-428-3270 ADAM THURMAN OWNER Field Comment: no stoppage found customer will call a plumber Sewer Back Up 10/02/19-15:55 10/02/19-15:55 10/03/19-14:39 Instructions: Sewer coming up in middle of road Field Comment: Repaired sewer leak in roadway, front of house. FZ Sewer Back Up 10/04/19-10:42 10/04/19-10:42 10/04/19-15:10 Instructions: Ittizen called in to report strong sewer smell on the corner of Stone and Paddgett street. Wants some one to come find the source of the odor. He will be waiting on his front porch Field Comment: customer needs cap on cleanout. talked with customer about that Sewer Back Up 10/04/19-15:48 10/07/19-15:48 10/07/19-12:29 Instructions: Plumber called and said sewer is backing up, there is no water connected. Field Comment: sewer coming out of pipe at empty lot. ran sewer main and cleared it. water, grit coming out. put li ne on sewer water Sewer Back Up 10/08/19-14:32 10/08/19-14:32 10/10/19-09:46 Instructions: toilets are backing up Field Comment: ran sewer main no stoppage found on city main Sewer Back Up 10/10/19-14:05 10/10/19-14:05 10/11/19-13:00 Instructions: ran city main and customer service line and cleared Sewer Back Up 10/11/19-13:33 10/11/19-13:33 10/15/19-08:30 Instructions: ran and cleared sewer service line Field Comment: ran and cleared sewer service line Sewer Back Up 10/15/19-07:43 10/13/19-10:33 10/13/19-11:20 Instructions: Sewer back up Field Comment: Customer did not have a clean out for us to run customers line. Customer to advise owner to contact plumber for repairs. Called out by dispatch. FZ Sewer Back Up 10/14/19-13:07 10/14/19-13:07 10/15/19-09:01 Instructions: Sewer Back Up Field Comment: Manny talked to them. ran sewer and it was clear Sewer Back Up 10/21/19-11:07 10/21/19-11:07 10/22/19-10:24 Instructions: flush sewer line Field Comment: run our sewer line Sewer Back Up 10/21/19-15:44 10/21/19-15:44 10/22/19-10:21 Instructions: run our sewer line Field Comment: rain main no stoppage found													
009-0006800-001	A	BIGHAM ROSSILITA 322 MC WHORTER STREET	12367	Sewer Back Up				1		10/03/19	9956992	10209074	
007-0015400-000	A	SAMPSON MARVIN 640 PADGETT	12378	Sewer Back Up				1		10/04/19	9955673	1015118	
002-0001800-000	I	VACANT 313 W. MC DONALD	12382	Sewer Back Up				1		10/07/19			
010-0001400-020	A	LOGAN'S PLACE 113 E. COMMENCE	12403	Sewer Back Up				1		10/10/19	9957270	12097374	
002-0022400-008	A	SERRANO HERNANDEZ JOSE 123 WOOD	12416	Sewer Back Up				1		10/11/19	8272260	10262124	
010-0000500-003	A	KINDNESS KOTTAGE 316 E. BROAD	12422	Sewer Back Up				1		10/15/19	9957383	10207478	
002-0001200-012	A	MATA MARIA C 310 W. BLAIR	12455	Sewer Back Up				1		10/13/19	10474322	10697934	
002-0021800-015	A	ORTEGA FRANCISCA 132 WOOD	12445	Sewer Back Up				1		10/15/19	10474143	10920447	
001-0005400-009	A	CANDELIARIO EMMA & FULGENCIO 526 W. BLAIR	12485	Sewer Back Up				1		10/22/19	9957275	12100406	
001-0027800-000	A	WILHITE CLAUDIA 330 W. KILPATRICK	12494	Sewer Back Up				1		10/22/19	9957283	12100085	

Account Number	S	Customer Name/Address Desc	T	Work Order Number	Work Order Description	Date/Time Issued	Date/Time Requested	Date/Time Completed	Units	Meter Reading	Read Date	Meter Number	Special Meter ID	Special Meter Id 2
010-0000700-002	I	VACANT		12508	Sewer Back Up	10/24/19-09:12	10/24/19-09:12	10/24/19-14:34	1		10/24/19	9957339	12098483	
		302 E. BROAD			Instructions: People in area say there is a really strong sewer smell coming from the demored building. Mayor cal led to ask that someone drive out there and check out the source of the smell. May be backup or may have hit a line. Unknown - CAK									
					Field Comment: walked around chevron and talked to people doing the demolishing and asked them if they smelled anyt hing. They said the haven't. Checked manhole on 80it was running fine. We did find a cleannout with out a cap and installed on									
007-0009700-007	A	CUMMINS SANDRA		12520	Sewer Back Up	10/28/19-09:06	10/28/19-09:06	10/28/19-15:51	1		10/28/19	9955662	12091292	
		716 N. PACIFIC			Instructions: SAYS TOILET FILLS UP WHEN SHE FLUSHES AND GURGLES. PLEASE RUN OUR LINE.									
					Field Comment: ran cleannout and unstopped it									
		Number of work orders:	13	Units:	13	Completed:	13	Not Completed:	0					