

MINEOLA WATER UTILITIES

MONTHLY ACTIVITY REPORT

MONTH OF: February, 2020

WATER:

Bacteriological Analysis.....	06
Pump Station Inspections.....	116 Hrs.
Customer Water Connections.....	24
Customer Water Disconnections.....	27
Turn water off for leak	06
Reread	01
Water Leaks Reported.....	03
Paid turn water back on	12
Locate Water Lines for Others.....	04
O & M Water Production & Distribution System (hours).....	464 hrs.
Miscellaneous	27
Pulled meter logs	01
Number of water Meters Read.....	2,710
Number of active accounts.....	2,461 29 city acct.
Disconnects for Non-Payment.....	28
Change meter register	01
Set Meter	00
Repairs complete turn water on.....	01
Lock Meters.....	01
PRODUCTION & TREATMENT	
Water Produced in Million Gallons.....	12.709 M.G.
Average Usage per Day.....	0.438 M.G.
Highest Usage per Day.....	0.514 M.G.
Pounds of Disinfectant Used.....	443 lbs.
Average Pounds of Disinfectant Used per Day.....	15.0 lbs.
Pounds. Of Sequestering Agent Used.....	104 .00 lbs.
Average Pounds of Sequestering agent used per Day.....	3.5 lbs.
Pounds of Fluoride Used.....	134 lbs.
Average pounds of Fluoride Used	4.6 lbs.

MINEOLA WATER UTILITY MONTHLY ACTIVITY REPORT

WASTEWATER:

Sewer Stoppages Reported.....	13
Lift Station Inspections Performed.....	058 hrs.
Sewer Taps Installed -----	0
O & M of Wastewater Collection System (hours).....	496 hrs.
Number of Feet of sewer Main cleared.....	1,300 ft.

UTILITY MAINTENANCE:

Vehicle Maintenance.....checked daily
Older trucks check for mechanical problems and returned to service.

Equipment Maintenance..... 116 hrs. EST.

Submitted by: Rolando Ortega

Water: Dept

Date: 3/06/2020