

**DEPARTMENT HEAD REPORT
WASTEWATER TREATMENT PLANT**

	May 2019	May 2020
GALLONS TREATED	38.762 MG	22.313 MG
AVERAGE GALLONS TREATED	1.25 MGD	.720 MGD
LABORATORY TESTS PERFORMED	328	328
MONTHLY REPORTS	01	01
RAIN FALL	11.35 INCHES	5.33 INCHES
RAIN FALL TO DATE	28.34 INCHES	29.37 INCHES

	PERMIT PARAMETERS	REPORTED
CBOD5/avg	10.0 mg/L	2.00
CBOD5/max	25.0 mg/L	2.00
CBOD5/lbs/day	167.0	11.5
TSS/avg	15.0 mg/L	1.95
TSS/max	40.0 mg/L	2.80
TSS/lbs/day	250.0	10.8
NH3-N/avg	2.0 mg/L	0.100
NH3-N/max	7.0 mg/L	0.100
NH3-N/lbs/day	33.0	0.574
D.O. minimum	4.0 mg/L	7.00
pH minimum	6.0 standard units	7.06
pH maximum	9.0 standard units	7.40
E. coli avg	126 colonies per 100 mil	0.344
E. coli 7dy/avg	394 colonies per 100 mil	1.49
2 Hour Peak Flow	4167 gpm	2430 gpm
Copper/avg		15.9 ug/L