

**DEPARTMENT HEAD REPORT
WASTEWATER TREATMENT PLANT**

	December 2019	December 2020
GALLONS TREATED	14.047 MG	16.349 MG
AVERAGE GALLONS TREATED	0.453 MGD	0.527 MGD
LABORATORY TESTS PERFORMED	328	328
MONTHLY REPORTS	01	01
RAIN FALL	1.24 INCHES	4.87 INCHES
RAIN FALL TO DATE	47.71 INCHES	53.04 INCHES

	PERMIT PARAMETERS	REPORTED
CBOD5/avg	10.0 mg/L	2.00
CBOD5/max	25.0 mg/L	2.40
CBOD5/lbs/day	167.0	10.1
TSS/avg	15.0 mg/L	3.80
TSS/max	40.0 mg/L	8.50
TSS/lbs/day	250.0	18.8
NH3-N/avg	2.0 mg/L	0.100
NH3-N/max	7.0 mg/L	0.100
NH3-N/lbs/day	33.0	0.487
D.O. minimum	4.0 mg/L	8.00
pH minimum	6.0 standard units	7.00
pH maximum	9.0 standard units	7.16
E. coli avg	126 colonies per 100 mil	0.617
E. coli 7dy/avg	394 colonies per 100 mil	1.81
2 Hour Peak Flow	4167 gpm	3087 gpm
Copper/avg		17.1 ug/L