

MINEOLA WATER UTILITIES

MONTHLY ACTIVITY REPORT

MONTH OF: **December, 2020**

WATER:

Bacteriological Analysis.....	06
Pump Station Inspections.....	124 Hrs.
Customer Water Connections.....	48
Customer Water Disconnections.....	40
Turn water off for leak	12
Reread	04
Water Leaks Reported.....	08
Paid turn water back on	15
Locate Water Lines for Others.....	01
O & M Water Production & Distribution System (hours).....	496 hrs.
Miscellaneous	13
Pulled meter logs	03
Number of water Meters Read.....	2,714
Number of active accounts.....	2,459 29 city acct.
Disconnects for Non-Payment.....	28
Change meter register	08
Set Meter	00
Repairs complete turn water on.....	06
Lock Meters.....	07
PRODUCTION & TREATMENT	
Water Produced in Million Gallons.....	16.101 M.G.
Average Usage per Day.....	0.519 M.G.
Highest Usage per Day.....	0.887 M.G.
Pounds of Disinfectant Used.....	539 lbs.
Average Pounds of Disinfectant Used per Day.....	17.0 lbs.
Pounds. Of Sequestering Agent Used.....	123 .00 lbs.
Average Pounds of Sequestering agent used per Day.....	4.0 lbs.
Pounds of Fluoride Used.....	147 lbs.
Average pounds of Fluoride Used	4.7 lbs.

MINEOLA WATER UTILITY MONTHLY ACTIVITY REPORT

WASTEWATER:

Sewer Stoppages Reported.....	11
Lift Station Inspections Performed.....	031 hrs.
Sewer Taps Installed -----	0
O & M of Wastewater Collection System (hours).....	496 hrs.
Number of Feet of sewer Main cleared.....	1,650 ft.

UTILITY MAINTENANCE:

Vehicle Maintenance.....checked daily
Older trucks check for mechanical problems and returned to service.

Equipment Maintenance..... 124 hrs. EST.

Submitted by: Rolando Ortega

Water: Dept

Date: 1/18/2021