

Account Number	S	Customer Name/Address Desc	Work Order Number	Work Order Description	Date/Time Issued	Date/Time Requested	Date/Time Completed	Units	Meter Reading	Read Date	Meter Number	Spectral Meter ID	Spectral Meter Id 2
006-0023400-003	A	MCDONALD'S OF MINEOLA #11434 1202 N. PACIFIC	14377	Sewer Back Up Instructions:	12/01/20-10:06	12/01/20-10:06	12/01/20-14:51	1		12/01/20	8398464	10325979	
003-0002200-001	A	POKERS GEORGE E 612 N. JOHNSON	14412	Sewer Back Up Instructions: Customer and other 4 houses next to him have sewer problems. Field Comment: rain main got it unstopped	12/04/20-10:47	12/04/20-10:47	12/07/20-10:41	1		12/07/20	9957142	12098808	
005-0012000-003	A	WALKER DERECK L 231 NUSS	14420	Sewer Back Up Instructions:	12/04/20-15:26	12/04/20-15:26	12/07/20-11:32	1		12/07/20	10070765	10186930	
010-0013000-013	A	THOMAS BOBBY 529 WREN	14438	Sewer Back Up Instructions: camera line per BOX plumbing ---- for Frankie Field Comment: camera customer clean out. problem is on customer side. marked it with green paint.	12/09/20-12:35	12/09/20-12:35	12/10/20-13:59	1		12/10/20	9708316	12099300	
004-0019100-001	A	BENJAMIN CHRISTY L 679 INWOOD	14440	Sewer Back Up Instructions: sewer is baking up. she wants someone to go look at it	12/09/20-12:57	12/09/20-12:57	12/10/20-14:01	1		12/10/20	9281161	12100331	
002-0022400-008	A	SERRANO HERNANDEZ JOSE 123 WOOD	14531	Sewer Back Up Instructions: 903-569-7846, sewer backing up into house. Call 903-352-5308 about the WO Field Comment:	12/21/20-10:40	12/21/20-10:40	12/22/20-09:30	1		12/22/20	8272260	10262124	
001-0018500-000	A	EVANS CHARLES W. 908 SYCAMORE	14537	Sewer Back Up Instructions: sewer backing up	12/22/20-08:05	12/22/20-08:05	12/22/20-09:00	1		12/22/20	9957161	12094799	
005-0012000-003	A	WALKER DERECK L 231 NUSS	14543	Sewer Back Up Instructions:	12/23/20-10:50	12/23/20-10:50	12/23/20-15:42	1		12/23/20	10070765	10186930	
004-0019100-001	A	BENJAMIN CHRISTY L 679 INWOOD	14545	Sewer Back Up Instructions: sewer backing up everywhere Field Comment: clear sewer lines	12/23/20-12:44	12/23/20-12:44	12/23/20-15:43	1		12/23/20	9281161	12100331	
001-0024900-018	A	WEAVER AMY 606 SYCAMORE	14554	Sewer Back Up Instructions:	12/28/20-13:32	12/25/20-12:56	12/25/20-14:30	1		12/25/20	9957246	12099395	
006-0013600-016	A	HUGHES RON 1414 N. NEWSOM	14546	Sewer Back Up Instructions: Ran customer clean out and cleared stoppage. Called out by dispatch. FZ Field Comment: ran main no stoppage found. Customer will call a plumber	12/28/20-11:45	12/28/20-11:45	12/29/20-11:28	1		12/29/20	10070995	10185492	

Number of work orders: 11 Units: 11 Completed: 11 Not Completed: 0