

**DEPARTMENT HEAD REPORT
WASTEWATER TREATMENT PLANT**

	June 2020	June 2021
GALLONS TREATED	16.815 MG	28.011 MG
AVERAGE GALLONS TREATED	0.560 MGD	.934 MGD
LABORATORY TESTS PERFORMED	328	328
MONTHLY REPORTS	01	01
RAIN FALL	0.98 INCHES	2.07 INCHES
RAIN FALL TO DATE	30.35 INCHES	27.31 INCHES

	PERMIT PARAMETERS	REPORTED
CBOD5/avg	10.0 mg/L	2.00
CBOD5/max	25.0 mg/L	2.00
CBOD5/lbs/day	167.0	16.1
TSS/avg	15.0 mg/L	3.00
TSS/max	40.0 mg/L	4.50
TSS/lbs/day	250.0	26.1
NH3-N/avg	2.0 mg/L	0.100
NH3-N/max	7.0 mg/L	0.100
NH3-N/lbs/day	33.0	0.798
D.O. minimum	4.0 mg/L	5.00
pH minimum	6.0 standard units	7.38
pH maximum	9.0 standard units	7.61
E. coli avg	126 colonies per 100 mil	0.775
E. coli 7dy/avg	394 colonies per 100 mil	2.50
2 Hour Peak Flow	4167 gpm	1337 gpm
Copper/avg		12.3 ug/L