

MINEOLA WATER UTILITIES
MONTHLY ACTIVITY REPORT

Month of: **October, 2021**

WATER:	
Bacteriological Analysis	06
Pump Station Inspections	124 Hrs.
Customer Water Connections	39
Customer Water Disconnections	39
Turn water off for leak	03
Reread	03
Water Leaks Reported	06
Paid turn water back on	19
Locate Water Lines for Others	02
O&M Water Production & Distribution System (hours)	496 hrs.
Miscellaneous	16
Pulled Meter Logs	03
Number of Water Meters Read	2,754
Number of Active Accounts (29 city acct.)	2,477
Disconnects for Non-Payment	32
Change Meter register	02
Set Meter	03
Repairs complete turn water on	01
Lock Meters	05
PRODUCTION & TREATMENT:	
Water Produced in Million Gallons	16.514 M.G.
Average Usage per Day	0.532 M.G.
Highest Usage per Day	0.765 M.G.
Pounds of Disinfectant Used	524 lbs.
Average Pounds of Disinfectant Used per Day	17.0 lbs.
Pounds of Sequestering Agent Used	141.00 lbs.
Average Pounds of Sequestering agent used per Day	4.5 lbs.
Pounds of Fluoride Used	235 lbs.

MINEOLA WATER UTILITIES
MONTHLY ACTIVITY REPORT

WASTEWATER:	
Sewer Stoppages Reported	04
Lift Station Inspections Performed	62 Hrs.
Sewer Taps Installed	1
O&M of Wastewater Collection System (hours)	496 Hrs.
Number of Feet of Sewer Main Cleared	600 ft.
UTILITY MAINTENANCE:	
Vehicle Maintenance	Checked Daily
Older trucks check for mechanical problems and returned to service	
Equipment Maintenance	120 hrs. EST.

Submitted by: Rolando Ortega