

MINEOLA WATER UTILITIES
MONTHLY ACTIVITY REPORT

Month of: December, 2021

WATER:	
Bacteriological Analysis	06
Pump Station Inspections	124 Hrs.
Customer Water Connections	48
Customer Water Disconnections	40
Turn water off for leak	12
Reread	07
Water Leaks Reported	08
Paid turn water back on	15
Locate Water Lines for Others	01
O&M Water Production & Distribution System (hours)	496 hrs.
Miscellaneous	14
Pulled Meter Logs	03
Number of Water Meters Read	2,758
Number of Active Accounts (29 city acct.)	2,480
Disconnects for Non-Payment	15
Change Meter register (Dead Batteries).	18
Set Meter	04
Repairs complete turn water on	06
Lock Meters	07
Leak at Meter	02
PRODUCTION & TREATMENT:	
Water Produced in Million Gallons	13.236 M.G.
Average Usage per Day	0.426 M.G.
Highest Usage per Day	0.641 M.G.
Pounds of Disinfectant Used	435 lbs.
Average Pounds of Disinfectant Used per Day	14.0 lbs.
Pounds of Sequestering Agent Used	127.00 lbs.
Average Pounds of Sequestering agent used per Day	4.1 lbs.
Pounds of Fluoride Used	206 lbs.

MINEOLA WATER UTILITIES
MONTHLY ACTIVITY REPORT

WASTEWATER:	
Sewer Stoppages Reported	11
Lift Station Inspections Performed	031 Hrs.
Sewer Taps Installed	1
O&M of Wastewater Collection System (hours)	496 Hrs.
Number of Feet of Sewer Main Cleared	1,650 ft.
UTILITY MAINTENANCE:	
Vehicle Maintenance	Checked Daily
Older trucks check for mechanical problems and returned to service	
Equipment Maintenance	124- hrs. EST.

Submitted by: Rolando Ortega