

MINEOLA WATER UTILITIES  
MONTHLY ACTIVITY REPORT

Month of:     December 2022

<b>WATER:</b>	
Bacteriological Analysis	06
Pump Station Inspections	124 Hrs.
Customer Water Connections	24
Customer Water Disconnections	41
Turn water off for leak	16
Reread	63
Water Leaks Reported	19
Paid turn water back on	13
Locate Water Lines for Others	10
O&M Water Production & Distribution System (hours)	496 hrs.
Miscellaneous	38
Pulled Meter Logs	04
Number of Water Meters Read	2,821
Number of Active Accounts (29 city acct.)	2,558
Disconnects for Non-Payment	32
Change Meter register (Dead Batteries).	10
Set Meter	00
Repairs complete turn water on	04
Lock Meters	04
Leak at Meter	02
<b>PRODUCTION &amp; TREATMENT:</b>	
Water Produced in Million Gallons	14.395 M.G.
Average Usage per Day	0.464 M.G.
Highest Usage per Day	1.027 M.G.
Pounds of Disinfectant Used	443 lbs.
Average Pounds of Disinfectant Used per Day	14.0 lbs.
Pounds of Sequestering Agent Used	82.00 lbs.
Average Pounds of Sequestering agent used per Day	2.6 lbs.
Pounds of Fluoride Used	185 lbs.

MINEOLA WATER UTILITIES  
MONTHLY ACTIVITY REPORT

<b>WASTEWATER:</b>	
Sewer Stoppages Reported	15
Lift Station Inspections Performed	62 Hrs.
Sewer Taps Installed	0
O&M of Wastewater Collection System (hours)	496 Hrs.
Number of Feet of Sewer Main Cleared	2,250 ft.
<b>UTILITY MAINTENANCE:</b>	
Vehicle Maintenance	Checked Daily
Older trucks check for mechanical problems and returned to service	
Equipment Maintenance	124 Hrs. EST.

Submitted by: Rolando Ortega