

MINEOLA WATER UTILITIES  
MONTHLY ACTIVITY REPORT

Month of:     **January 2023**

<b>WATER:</b>	
Bacteriological Analysis	06
Pump Station Inspections	124 Hrs.
Customer Water Connections	40
Customer Water Disconnections	46
Turn water off for leak	09
Reread	214
Water Leaks Reported	11
Paid turn water back on	13
Locate Water Lines for Others	02
O&M Water Production & Distribution System (hours)	496 hrs.
Miscellaneous	18
Pulled Meter Logs	01
Number of Water Meters Read	2,823
Number of Active Accounts (29 city acct.)	2,548
Disconnects for Non-Payment	39
Change Meter register (Dead Batteries).	00
Set Meter	00
Repairs complete turn water on	05
Lock Meters	06
Leak at Meter	01
<b>PRODUCTION &amp; TREATMENT:</b>	
Water Produced in Million Gallons	13.354 M.G.
Average Usage per Day	0.430 M.G.
Highest Usage per Day	0.639 M.G.
Pounds of Disinfectant Used	461 lbs.
Average Pounds of Disinfectant Used per Day	14.9 lbs.
Pounds of Sequestering Agent Used	92.00 lbs.
Average Pounds of Sequestering agent used per Day	3.0 lbs.
Pounds of Fluoride Used	135 lbs.

MINEOLA WATER UTILITIES  
MONTHLY ACTIVITY REPORT

<b>WASTEWATER:</b>	
Sewer Stoppages Reported	10
Lift Station Inspections Performed	124 Hrs.
Sewer Taps Installed	0
O&M of Wastewater Collection System (hours)	496 Hrs.
Number of Feet of Sewer Main Cleared	1,500 ft.
<b>UTILITY MAINTENANCE:</b>	
Vehicle Maintenance	Checked Daily
Older trucks check for mechanical problems and returned to service	
Equipment Maintenance	124 Hrs. EST.

Submitted by: Rolando Ortega