

MINEOLA WATER UTILITIES
MONTHLY ACTIVITY REPORT

Month of: **June 2023**

WATER:	
Bacteriological Analysis	06
Pump Station Inspections	120 Hrs.
Customer Water Connections	44
Customer Water Disconnections	42
Turn water off for leak	02
Reread	09
Water Leaks Reported	13
Paid turn water back on	15
Locate Water Lines for Others	03
O&M Water Production & Distribution System (hours)	480 hrs.
Miscellaneous	14
Pulled Meter Logs	01
Number of Water Meters Read	2,840
Number of Active Accounts (29 city acct.)	2,567
Disconnects for Non-Payment	108
Change Meter register (Dead Batteries).	60
Set Meter	05
Repairs complete turn water on	01
Lock Meters	01
Leak at Meter	00
Check for stopped Meter	02
PRODUCTION & TREATMENT:	
Water Produced in Million Gallons	15.852 M.G.
Average Usage per Day	0.528 M.G.
Highest Usage per Day	0.836 M.G.
Pounds of Disinfectant Used	519 lbs.
Average Pounds of Disinfectant Used per Day	17.3 lbs.
Pounds of Sequestering Agent Used	106.00 lbs.
Average Pounds of Sequestering agent used per Day	3.5 lbs.

MINEOLA WATER UTILITIES
MONTHLY ACTIVITY REPORT

WASTEWATER:	
Sewer Stoppages Reported	04
Lift Station Inspections Performed	120 Hrs.
Sewer Taps Installed	0
O&M of Wastewater Collection System (hours)	480 Hrs.
Number of Feet of Sewer Main Cleared	600 ft.
UTILITY MAINTENANCE:	
Vehicle Maintenance	Checked Daily
Older trucks check for mechanical problems and returned to service	
Equipment Maintenance	120 Hrs. EST.

Submitted by: Rolando Ortega