

MINEOLA WATER UTILITIES
MONTHLY ACTIVITY REPORT

Month of: **October 2023**

WATER:	
Bacteriological Analysis	06
Pump Station Inspections	124 Hrs.
Customer Water Connections	47
Customer Water Disconnections	43
Turn water off for leak	03
Reread	85
Water Leaks Reported	17
Paid turn water back on	10
Locate Water Lines for Others	05
O&M Water Production & Distribution System (hours)	496 hrs.
Miscellaneous	23
Pulled Meter Logs	07
Number of Water Meters Read	2,869
Number of Active Accounts (29 city acct.)	2,582
Disconnects for Non-Payment	45
Change Meter register (Dead Batteries).	55
Set Meter	00
Repairs complete turn water on	04
Lock Meters	07
Leak at Meter	02
Check for stopped Meter	00
PRODUCTION & TREATMENT:	
Water Produced in Million Gallons	15.181 M.G.
Average Usage per Day	0.489 M.G.
Highest Usage per Day	0.567 M.G.
Pounds of Disinfectant Used	531 lbs.
Average Pounds of Disinfectant Used per Day	17.0 lbs.
Pounds of Sequestering Agent Used	99.00 lbs.
Average Pounds of Sequestering agent used per Day	3.2 lbs.

MINEOLA WATER UTILITIES
MONTHLY ACTIVITY REPORT

WASTEWATER:	
Sewer Stoppages Reported	03
Lift Station Inspections Performed	124 Hrs.
Sewer Taps Installed	2
O&M of Wastewater Collection System (hours)	496 Hrs.
Number of Feet of Sewer Main Cleared	450 ft.
UTILITY MAINTENANCE:	
Vehicle Maintenance	Checked Daily
Older trucks check for mechanical problems and returned to service	
Equipment Maintenance	124 Hrs. EST.

Submitted by: Rolando Ortega