

MINEOLA WATER UTILITIES  
MONTHLY ACTIVITY REPORT

Month of:    **March 2024**

<b>WATER:</b>	
Bacteriological Analysis	06
Pump Station Inspections	124 Hrs.
Customer Water Connections	37
Customer Water Disconnections	32
Turn water off for leak	06
Reread	12
Water Leaks Reported	09
Paid turn water back on	11
Locate Water Lines for Others	2
O&M Water Production & Distribution System (hours)	496 hrs.
Miscellaneous	22
Pulled Meter Logs	03
Number of Water Meters Read	2,876
Number of Active Accounts (29 city acct.)	2,583
Disconnects for Non-Payment	28
Change Meter register (Dead Batteries).	34
Set Meter	07
Repairs complete turn water on	04
Lock Meters	12
Leak at Meter	05
<b>Check for stopped Meter</b>	<b>03</b>
<b>PRODUCTION &amp; TREATMENT:</b>	
Water Produced in Million Gallons	14.420 M.G.
Average Usage per Day	0.465 M.G.
Highest Usage per Day	0.679 M.G.
Pounds of Disinfectant Used	522 lbs.
Average Pounds of Disinfectant Used per Day	16.8 lbs.
Pounds of Sequestering Agent Used	101.48 lbs.
Average Pounds of Sequestering agent used per Day	3.2 lbs.

MINEOLA WATER UTILITIES  
MONTHLY ACTIVITY REPORT

<b>WASTEWATER:</b>	
Sewer Stoppages Reported	09
Lift Station Inspections Performed	62 Hrs.
Sewer Taps Installed	0
O&M of Wastewater Collection System (hours)	496 Hrs.
Number of Feet of Sewer Main Cleared	1,350 ft.
<b>UTILITY MAINTENANCE:</b>	
Vehicle Maintenance	Checked Daily
Older trucks check for mechanical problems and returned to service	
Equipment Maintenance	124 Hrs. EST.

Submitted by: Rolando Ortega