MINEOLA WATER UTILITIES MONTHLY ACTIVITY REPORT

Month of: July 2024

| WATER: | |
|--|-------------|
| Bacteriological Analysis | 06 |
| Pump Station Inspections | 124 Hrs. |
| Customer Water Connections | 47 |
| Customer Water Disconnections | 43 |
| Turn water off for leak | 05 |
| Reread | 08 |
| Water Leaks Reported | 37 |
| Paid turn water back on | 14 |
| Locate Water Lines for Others | 03 |
| O&M Water Production & Distribution System (hours) | 496 hrs. |
| Miscellaneous | 42 |
| Pulled Meter Logs | 09 |
| Number of Water Meters Read | 2,903 |
| Number of Active Accounts (29 city acct.) | 2,604 |
| Disconnects for Non-Payment | 30 |
| Change Meter register (Dead Batteries). | 47 |
| Set Meter | 04 |
| Repairs complete turn water on | 01 |
| Lock Meters | 12 |
| Leak at Meter | 01 |
| Check for stopped Meter | 02 |
| PRODUCTION & TREATMENT: | |
| Water Produced in Million Gallons | 17.366 M.G. |
| Average Usage per Day | 0.560 M.G. |
| Highest Usage per Day | 0.733 M.G. |
| Pounds of Disinfectant Used | 643 lbs. |
| Average Pounds of Disinfectant Used per Day | 20.7 lbs. |
| Pounds of Sequestering Agent Used | 151.00 lbs. |
| Average Pounds of Sequestering agent used per Day | 4.8 lbs. |

MINEOLA WATER UTILITIES MONTHLY ACTIVITY REPORT

| WASTEWATER: | |
|--|---------------|
| Sewer Stoppages Reported | 5 |
| Lift Station Inspections Performed | 62 Hrs. |
| Sewer Taps Installed | 0 |
| O&M of Wastewater Collection System (hours) | 496 Hrs. |
| Number of Feet of Sewer Main Cleared | 750 ft. |
| | |
| UTILITY MAINTENANCE: | |
| Vehicle Maintenance | Checked Daily |
| Older trucks check for mechanical problems and returned to | |
| service | |
| Equipment Maintenance | 155 Hrs. EST. |

Submitted by: Rolando Ortega