

MINEOLA WATER UTILITIES
MONTHLY ACTIVITY REPORT

Month of: **August 2024**

WATER:	
Bacteriological Analysis	06
Pump Station Inspections	062 Hrs.
Customer Water Connections	32
Customer Water Disconnections	34
Turn water off for leak	02
Reread	02
Water Leaks Reported	45
Paid turn water back on	24
Locate Water Lines for Others	06
O&M Water Production & Distribution System (hours)	496 hrs.
Miscellaneous	28
Pulled Meter Logs	05
Number of Water Meters Read	2,912
Number of Active Accounts (29 city acct.)	2,622
Disconnects for Non-Payment	36
Change Meter register (Dead Batteries).	46
Set Meter	05
Repairs complete turn water on	01
Lock Meters	07
Leak at Meter	02
Check for stopped Meter	01
PRODUCTION & TREATMENT:	
Water Produced in Million Gallons	20.683 M.G.
Average Usage per Day	0.667 M.G.
Highest Usage per Day	0.815 M.G.
Pounds of Disinfectant Used	766 lbs.
Average Pounds of Disinfectant Used per Day	24.7 lbs.
Pounds of Sequestering Agent Used	170.00 lbs.
Average Pounds of Sequestering agent used per Day	5.5 lbs.

MINEOLA WATER UTILITIES
MONTHLY ACTIVITY REPORT

WASTEWATER:	
Sewer Stoppages Reported	5
Lift Station Inspections Performed	62 Hrs.
Sewer Taps Installed	0
O&M of Wastewater Collection System (hours)	496 Hrs.
Number of Feet of Sewer Main Cleared	750 ft.
UTILITY MAINTENANCE:	
Vehicle Maintenance	Checked Daily
Older trucks check for mechanical problems and returned to service	
Equipment Maintenance	124 Hrs. EST.

Submitted by: Rolando Ortega