

PUBLIC WORKS

September (8/22-9/11)

Wastewater

- Normal ground maintenance & lab work
- Hired new operator at the plant
- Catching up on general upkeep due to being short staffed for awhile
- Getting problems addressed with the UV system, the new UV system has been throwing alarms & are tackling the problems.
- Had a gear box go out that is from the 1990's & waiting on parts to arrive which should be here in the next couple weeks
- Working on drainage issues
- Actively working on the yearly sludge report that is due at the end of the month, as we had to haul off a lot due to filling in the old aeration basin
- Currently dealing with the biomonitoring that happens quarterly.
- The outfall had some downed trees and obstructions that got cleaned up & cleared out