

MINEOLA WATER UTILITIES  
MONTHLY ACTIVITY REPORT

Month of:     **September 2024**

<b>WATER:</b>	
Bacteriological Analysis	06
Pump Station Inspections	060 Hrs.
Customer Water Connections	32
Customer Water Disconnections	30
Turn water off for leak	06
Reread	04
Water Leaks Reported	38
Paid turn water back on	15
Locate Water Lines for Others	01
O&M Water Production & Distribution System (hours)	480 hrs.
Miscellaneous	12
Pulled Meter Logs	08
Number of Water Meters Read	2,913
Number of Active Accounts (29 city acct.)	2,623
Disconnects for Non-Payment	26
Change Meter register (Dead Batteries).	49
Set Meter	00
Repairs complete turn water on	02
Lock Meters	09
Leak at Meter	01
<b>Check for stopped Meter</b>	<b>07</b>
<b>PRODUCTION &amp; TREATMENT:</b>	
Water Produced in Million Gallons	19.840 M.G.
Average Usage per Day	0.661 M.G.
Highest Usage per Day	0.863 M.G.
Pounds of Disinfectant Used	712 lbs.
Average Pounds of Disinfectant Used per Day	23.7 lbs.
Pounds of Sequestering Agent Used	170.00 lbs.
Average Pounds of Sequestering agent used per Day	5.6 lbs.

MINEOLA WATER UTILITIES  
MONTHLY ACTIVITY REPORT

<b>WASTEWATER:</b>	
Sewer Stoppages Reported	5
Lift Station Inspections Performed	60 Hrs.
Sewer Taps Installed	0
O&M of Wastewater Collection System (hours)	480 Hrs.
Number of Feet of Sewer Main Cleared	750 ft.
<b>UTILITY MAINTENANCE:</b>	
Vehicle Maintenance	Checked Daily
Older trucks check for mechanical problems and returned to service	
Equipment Maintenance	120 Hrs. EST.

Submitted by: Rolando Ortega