

PUBLIC WORKS

December (11/21-12/11)

Wastewater

- Normal ground maintenance & lab work.
- Finished the DMRQA-44 study with all the corrective measures taken for TCEQ and the EPA.
- Resealed the baffle in clarifier 2.
- Replumbed the hose bibs around the plant, they were old and leaking.
- Worked on some of the drainage issues.
- Replaced the stabilizer arms for the zero-turn mower.