

PUBLIC WORKS

January (12/12-1/21)

Wastewater

- Normal ground maintenance & lab work.
- Working on beaver dams that are being built in the receiving stream of the plant.
- A portion of headworks went down due to age/mechanical failure, and we are in the process of getting new equipment installed.
- RAS pump was shimmed and readjusted.
- Due to the rain, we worked on erosion issues.