

# MINEOLA WATER UTILITIES MONTHLY ACTIVITY REPORT

**Month of:     December 2024**

<b>WATER:</b>	
Bacteriological Analysis	06
Pump Station Inspections	62 Hrs.
Customer Water Connections	26
Customer Water Disconnections	30
Turn water off for leak	07
Reread	02
Water Leaks Reported	47
Paid turn water back on	08
Locate Water Lines for Others	06
O&M Water Production & Distribution System (hours)	496 hrs.
Miscellaneous	29
Pulled Meter Logs	14
Number of Water Meters Read	2,919
Number of Active Accounts (29 city acct.)	2,622
Disconnects for Non-Payment	31
Change Meter register (Dead Batteries).	16
Set Meter	00
Repairs complete turn water on	02
Lock Meters	02
Leak at Meter	01
<b>Check for stopped Meter</b>	<b>05</b>
<b>PRODUCTION &amp; TREATMENT:</b>	
Water Produced in Million Gallons	13.376 M.G.
Average Usage per Day	0.431 M.G.
Highest Usage per Day	0.513 M.G.
Pounds of Disinfectant Used	476 lbs.
Average Pounds of Disinfectant Used per Day	15.0 lbs.
Pounds of Sequestering Agent Used	137.00 lbs.
Average Pounds of Sequestering agent used per Day	5.0 lbs.

MINEOLA WATER UTILITIES  
MONTHLY ACTIVITY REPORT

<b>WASTEWATER:</b>	
Sewer Stoppages Reported	12
Lift Station Inspections Performed	62 Hrs.
Sewer Taps Installed	0
O&M of Wastewater Collection System (hours)	496 Hrs.
Number of Feet of Sewer Main Cleared	1,800 ft.
<b>UTILITY MAINTENANCE:</b>	
Vehicle Maintenance	Checked Daily
Older trucks check for mechanical problems and returned to service	
Equipment Maintenance	124 Hrs. EST.

Submitted by: Rolando Ortega