

PUBLIC WORKS

January (12/12-1/21)

Water

- City hall work orders; 113 completed.
- Changed out 91 dead registers.
- Worked on weeklies
- Ran trouble spots
- Checked SCBA's, did SCBA class with David Madsen
- Read meters and did 25 cut offs for the month of December
- Read meter and did 33 cut offs for the month of January
- Flushed end lines
- Turned on heat lamps & space heaters at wells and pump stations for freezing weather temperatures
- Worked on re-reads and old work orders that needed to be closed
- Greased air relief valves at Taylor LS
- Added treatment to Kevin and Brenlind lift stations
- Set trench box for Stubbs making a 4" sewer line bore on Loop 564
- Ran and cleared sewer clean out for stoppage at 1602 Country Club
- Tapped 6" sewer main for new sewer service at 390 N Loop 564, bore under loop 564 and encased 4" PVC pipe with 8" steel casing
- Replaced ¾" shut off valve on service line at 924 Mimosa
- Ran and cleared sewer clean out for stoppage at 409 Boundary
- Ran and cleared sewer clean out for stoppage at Christus clinic
- Fixed 2" water leak at 713 W Buchanan

- Fixed broken 4” sewer line at 218 Harris
- Checked 1” leak at 226 Cheek Street, leak on customers side
- Fixed water leak on service lines at corner of Dawn and Mimosa Street, service not located and hit by contractors
- Located water and sewer lines for Double S Drilling at 1810 N Pacific
- Located water and sewer lines for SWEPCO at 1717 W Broad, installing pole and anchor
- Located water and sewer lines for Red Underground at 105 Maxine
- Located water and sewer lines for CenterPoint Energy at 327 Read Street
- Located water and sewer lines for Stubbs contractors burying fiber for Peoples on Circle Drive, Emily, Inwood, Kevin, Mimosa from Peachtree to Dawn Drive to East Broad Street

